

Ashland Water and Sewer Department  
Minutes  
July 17, 2018

The meeting was called to order at 6:30 a.m. Mr. Toth, and Mr. Cilley present. Mr. Badger absent with notice.

The Commissioners discussed the 90% design drawings with Steve Bullard. The discussion focused on the by-pass design. Steve recommended several changes including using a plug instead of valves, increasing the size and depth of the chamber to accommodate periods of high flow, and designing the chamber so that influent from the other side of town can be accommodated in the future.

Submitted  
David Toth  
Chair, Ashland water and Sewer Commission