



Town of Ashland, New Hampshire

20 HIGHLAND STREET • P.O. BOX 517 • ASHLAND, NEW HAMPSHIRE 03217-0517
TOWN OFFICE (603) 968-4432 FAX (603) 968-3776

Ashland Wastewater Treatment Facility Septage Regulations

1. New Haulers

- a. The acceptance or rejection of all new haulers is at the sole discretion of the Town of Ashland
- b. New haulers must fill out the department's Hauled Waste Discharge Permit
- c. New haulers must fill out an application with the utilities billing department.
- d. The application fee must be paid in full.

2. Accounts

- a. Accounts are billed on a monthly basis.
- b. Please see attached for current rates.
- c. Haulers are responsible for correctly filling out septage receiving forms when dumping. The department shall not be responsible for any errors that occurred when haulers fill out forms.
- d. Bills will be paid IN FULL by the due date listed.
 - i. Partial payments will not be accepted.
- e. If payment is not received in full on or before the date, dumping privileges shall be revoked.

3. Hours and Location

- a. The treatment facility is located at: 137 Collins Street, Ashland, NH
 - i. The septage building is the building when you drive through the gate.
- b. A key fob for the gate and septage receiving facility will be issued after application is accepted.
- c. The hours of operation are 7am-7pm all week.
 - i. Weekends the gate will be locked so haulers will need a key fob to get in.

4. Septage Disposal Procedures

- a. Haulers are expected to use septage building when dumping.



Town of Ashland, New Hampshire

20 HIGHLAND STREET • P.O. BOX 517 • ASHLAND, NEW HAMPSHIRE 03217-0517
TOWN OFFICE (603) 968-4432 FAX (603) 968-3776

- i. Haulers are expected to keep the septage offload station area clean when dumping. If any leakage or spillage occurs, it is their responsibility clean it up. A water hose is available during the summer and at request in the winter.
 - ii. There are two offload stations, so please only take one spot.
 - iii. Alert plant operations of any issues with stations or if more slips are needed.
 - b. Haulers must fill out septage record slips accurately and completely.
 - c. Haulers must be cordial with other haulers and plant operations.
 - d. We will not accept any high concentration grease loads, industrial waste, or any waste that the department determines could be detrimental to operations.
 - i. The department will only allow septage with a PH between 6.0 and 10 su
 1. If there are any concerns that the load does not fall in this range the department shall test it to make sure of compliance with this rule.
5. RV
- a. The acceptance or rejection of RV waste will be at the discretion of the department.
6. Rates
- a. See *Ashland Wastewater Treatment Facility Septage Rates*